



INSTITUT TECHNOLOGIQUE

INSTITUT TECHNOLOGIQUE

FCBA

Fire Laboratory

10 rue Galilée - 77420 Champs-sur-Marne

Laboratory approved by the Ministry for the Interior

JO of February 10, 2007

OFFICIAL REPORT OF CLASSIFICATION OF FIRE PERFORMANCE

Of A MATERIAL ENVISAGED IN ARTICLE 5

DECREE OF November 21, 2002

N° **CM - 19 - P - 052**

Valid 5 years as from jeudi 21 avril 2016

Trade mark: **MOLTON**

Summary description

Kind of textile **tissé**

Composition **100% coton**

Mass per unit area **300 g/m² - épaisseur : 1,2 mm**

Kind of Fire retardant **1 application - 34 g/m²**

Color **tous coloris**

Nature of the test : **Electrical burner test**
Artificial ageing in climatic chamber

Classification : **M1**

Observations :

Durability of the classification (Article 5 de l'annexe 2) **Not limited**

Usual term **Walls hung covering, sheers, curtains,...**

Cleaning conditions **Not washable with water and not cleanable**

Taking into account the criteria resulting from the tests annexed described in the test report N° **FE 19-0026-0119 / 367160236**

This official report attests only characteristics of the sample submitted for testing and does not prejudice similar characteristics of products. It thus does not constitute a certification of products within the meaning of the L.115-27 article of the code of the consumption and the law of June 3rd, 1994.

NOTE: The integral reproductions and by photocopy of this official report of classification are only authorized or the official report unit of classification and report of annexed test. These conclusions relate only to the resistance / reaction to fire performance of the element that is the subject of the present classification report. They do not prejudice, in any case, other performances related to its incorporation to a work "

"Not legally acceptable for any use under the pretence of the article AM 18 (Decree of March 6th, 2006) for upholstered seat"

Champs-sur-Marne, le **lundi 6 mai 2019**

Technicienne d'essais
du Laboratoire Feu

Clotilde ETIEMVRE



Only the french version remains valide

Institut technologique FCBA : Forêt, Cellulose, Bois, Construction, Ameublement

Siège social
10 rue Galilée
77420 Champs-sur-Marne
Tél + 33 (0)1 72 84 97 84
www.fcba.fr
Siret 775 680 903 00132
APE 7219 Z
Code TVA CEE : FR 14 775 680 903